

CERTIFICATE OF COMPLIANCE

Certificate Number 20160406-E210412
Report Reference E210412-20160128
Issue Date 2016-APRIL-06

Issued to: DIGITAL ELECTRONICS CORP
Schneider Electric Osaka Bldg
4-4-9 Kitahama
Chuo-Ku , Osaka 541-0041
Japan

This is to certify that representative samples of Programmable Controllers for Use in Hazardous Locations
Industrial Box PC and display: PFXPU2(%),PFXPP2(%)
Note: (%) : Model followed by 12 letters or numbers.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/ISA 12.12.01 - Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations
CAN/CSA C22.2 No. 213-M1987 - Non-incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

